

Table1: Bypasses and Overflows with Volumes in cubic metres and duration in hours for 2022

Site	Date	Duration Hrs.	Raw overflow	Raw bypass	Primary Treated bypass/Overflow	Primary Bypass/Overflow (Secondary Treated)
Adelaide WWTP	17-Feb-22	17.55			2,792	
Greenway WWTP	17-Feb-22	7.12		35	15,097	
Oxford WWTP	17-Feb-22	5.05			456	
Pottersburg WWTP	17-Feb-22	20.40	11,441			
Vauxhall WWTP	17-Feb-22	4.60			230	7,123
Berkshire PS	17-Feb-22	3.42	622			
Byron PS	17-Feb-22	5.37	604			
Medway PS	17-Feb-22	4.05	2,648			
Adelaide PS	17-Feb-22	5.00	698			
Pottersburg WWTP	22-Feb-22	8.12	929			
Vauxhall WWTP	21-May-22	0.28				318
Pottersburg WWTP	10-Jun-22	4.83				5,175
Vauxhall WWTP	20-Jul-22	0.43				307
Vauxhall WWTP	01-Aug-22	0.20				201
Vauxhall WWTP	04-Aug-22	2.00	783		1,229	1,732
Vauxhall WWTP	08-Aug-22	0.37				535